Certificate of Compliance

Certificate Number(s):

UL-US-2575247-0

Report Reference:

E541576-20250703

Issue Date:

2025-07-28

Issued to:

CET Electric Technology Inc
8/F Westside Building 201 Terra Industrial & Tradepark Che Gong Miao, Shenzhen, Guangdong, 518040, CN

This certificate confirms that representative samples of:
PICQ - Measuring, Testing and Signal-generation Equipment

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 61010-2-030, Edition 2, Issue Date 2018-12-21, Revision Date 2023-05-24
UL 61010-1, Edition 3, Issue Date 2012-05-11, Revision Date 2024-11-15

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-2575247-0
Report reference: E541576-20250703
Issue Date: 2025-07-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Advanced Power Quality Analyzer

Model(s): iMeter 8 *followed by A or B, followed by 5, 1, SCCPA or SCCT, followed by 9, followed by 2 or 3, followed by 5 or 6, followed by A, B, C or D, followed by NAA, followed by C or E.*

David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.

Certificate of Compliance

Certificate Number(s):

UL-CA-2555339-0

Report Reference:

E541576-20250703

Issue Date:

2025-07-28

Issued to:

CET Electric Technology Inc
8/F Westside Building 201 Terra Industrial & Tradepark Che Gong Miao, Shenzhen, Guangdong, 518040, CN

This certificate confirms that representative samples of:

PICQ7 - Measuring, Testing and Signal-generation Equipment Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 No. 61010-2-030, 2nd Ed., Issue Date: 2018-12-21
CSA C22.2 No. 61010-1:12, Edition 3, Issue Date 2012-05, Revision Date 2024-11

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-2555339-0
Report reference: E541576-20250703
Issue Date: 2025-07-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Advanced Power Quality Analyzer

Model(s): iMeter 8 *followed by A or B, followed by 5, 1, SCCPA or SCCT, followed by 9, followed by 2 or 3, followed by 5 or 6, followed by A, B, C or D, followed by NAA, followed by C or E.*

David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.